



GENERAL NOTES:

1. CONCRETE SHALL BE CLASS B.
2. CAST-IN-PLACE CONCRETE WALLS SHALL BE FORMED ON BOTH SIDES.
3. STEPS SHALL BE PROVIDED WHEN INLET DIMENSION "H" EXCEEDS 3'-6" AND SHALL BE IN ACCORDANCE WITH AASHTO M 199.
4. ALL INLETS SHALL BE CONSTRUCTED ON GRADE PER DESIGN PROFILE.
5. ALL INLETS SHOULD BE STAMPED SEE DETAIL U-C05 PHASE II LID.

